



1115 Vista Park Drive  
Post Office Box 269  
Forest, Virginia 24551  
(434) 316-6001 ♦ (434) 316-6002 – Fax

## ADDENDUM NO. 2 (1 page)

### PROJECT INFORMATION

Agency Name: DMHMRSAS  
Project Title: Central State Hospital Building 113 Roof  
Replacement  
DMHMRSAS Project Code: 720-17227-03-01  
DGS Project Code: 720-17227-006  
IFB No. 07-17

To: All Plan Holders  
Via: Facsimile

From: Scott Burger  
Date: November 27, 2007

The following constitutes Addendum No. 2 for the referenced project. Bidders must acknowledge receipt of all addenda as required on the bid form.



#### **Additional Questions Received to Date:**

1. Drawing A-2: The tapered system per plan is inadequate. I have taken the plans to a tapered engineer and the specs have been changed accordingly. I am sending a drawing and specs of the changes. Are these changes acceptable?

**Answer:** *The insulation taper slope varies to create a uniform insulation height at the outer perimeter of the building. Alternate tapering schemes cannot be considered prior to bidding but can be evaluated after a contract is awarded in accordance with Section 26(c) of the General Conditions of the Construction Contract (Form CO-7, DGS-30-054).*